

Responsible Refrigerant Planning for Retail Enterprises

State of the Industry

Andre Patenaude

Emerson Climate Technologies

Director CO₂ Business Development



25-26 June 2015 — Atlanta, Georgia




Objective

**To Show how a Retail Operation with
100 Stores
can Lower its Weighted GWP
while Increasing
New Stores by 3% /yr Using;**

- 1. Steady Approach**
- 2. Aggressive Approach**



Three System Architectures Offer Lowest LCCP* Choices in Supermarket Applications



Direct
Global
Warming

+

Indirect
Global
Warming



All Calculations were based
On St Louis, MO location

Primary could use
Lower GWP, A1 or
A2L (HFO/HFC) Blends:
Applicable to all Climates

LCCP* Life Cycle Climate Performance

<https://apps.emersonclimate.com/LCCP/PerformEnergyCalc.htm>

Sample Refrigerant Phase-Down Analysis (Using Minimum LCSP Systems)

Steady Approach

100-Store Chain

Builds: Three New Stores/Year (3%)

Baseline: 50% R404A and 50% R22 Centralized System Architectures & Refrigerants Changes

1. Retrofits:



- 5 Refrigerant Retrofits/yr to R448A or R449A for 10yrs to Eliminate R22
- 3 Retrofits/yr to R448A or R449A/Year for 15 year Periods to nearly eliminate R404A

2. Remodels:

- 1 Remodels/year to either Hybrid CO₂ Cascade or CO₂ Secondary with R448A or R449A on Primary
- Starting 2025 1 Remodel /yr (HFO-Blend <300GWP) Distributed





3. New Construction:

- 2 Stores/yr to CO₂ Booster
- 1 store per year, either Hybrid CO₂ Cascade or Secondary with R448A or R449A on high stage or Distributed.



LCCP and Weighted GWP

Steady Approach



Sample Refrigerant Phase-Down Analysis (Using Minimum LCSP Systems)

Aggressive Approach

100-Store Chain

Builds: 3 New Stores/Year (3%)

**Baseline: 50% R404A and 50% R22 in
Centralized Systems**

System Architectures & Refrigerants Changes

1. Retrofits:

- 5 Refrigerant Retrofits /yr. to R448A or R449A for 10 yrs to Eliminate R22
- 5 Retrofits /yr. to R448A or 449A/Year for 10 year to Eliminate R404A

2. Remodels:



- 3 CO₂ Booster Remodels/year (Replace R22 Fleet)
- 2 Hybrid CO₂ Cascade, or CO₂ Secondary with R448A or R449A high stage (Replace R22 Fleet)

3. New Construction

- 2 CO₂ Boosters /yr.
- 1 store per year, either Hybrid CO₂ Cascade or CO₂ Secondary with R448A or R449A on high stage







25-26 June 2015 — Atlanta, Georgia



*Assumes 15% leakage rates on centralized and distributed

LCCP and Weighted GWP


Aggressive Approach




Summary of Both Approaches

Retrofits: 8/yr to eliminate R22 & R404A
Remodels: 1/yr Cascade or Secondary,
 in 2025 1/yr w/ <300GWP Refrigerant
New Const: 3 Stores/yr : 2 CO₂ Booster, 1 Cascade

Retrofits: 10/yr to eliminate R22 & R404A
Remodels: 5/yr: 3/yr CO₂ Booster, 2/yr Cascade
New Const: 3 Stores/yr : 2 CO₂ Booster, 1 Cascade



Steady Approach



Aggressive Approach

Takeaways

Responsible Refrigerant Planning for Retail Enterprises

- 1. Reduction in CO₂e is Possible While Adding New Stores***
- 2. Remodelled & New Store with CO₂ Booster, Dramatically Reduces Weighted GWP of Your Enterprise Quickly***
- 3. By Factoring Warm Ambient Strategies into CO₂ Booster Architecture, Results Would Significantly Improve***

Thank You



25-26 June 2015 – Atlanta, Georgia

